

**Chief Executive Order No. 401/2011**

Exercising the authority vested in him by Article 50 of the Basic Law of the Special Administrative Region of Macau, and pursuant to Article 5, No. 2 of Law No. 5/2011 (Regime for the prevention and control of tobacco use), the Chief Executive orders as follows:

1. The smoking rooms referred to in sections 4), 7) and 8) of No. 1 of Article 5 of Law No. 5/2011 (Regime for the prevention and control of tobacco use) must meet the following general requirements:

- 1) Have signs posted;
  - 2) Be physically separated from the rest of the facilities, or have a ventilation system that prevents the spread of smoke to adjacent areas;
  - 3) Be equipped with direct ventilation to the outdoors through an air extraction system.
2. The size of the smoking rooms cannot be more than 20% of the total area intended for the public.
3. The surface covering of the ceilings, walls and floors of the smoking rooms must prevent the leakage of smoke, and the doors must be sliding doors with an automatic closing device.
4. Smoking rooms must have a separate ventilation system and have negative atmospheric pressure in relation to the adjacent areas.
5. Those in charge of the smoking rooms must see to the repair and regular maintenance of the ventilation system.
6. The entrances to the smoking rooms are to have signs prominently displayed, with the posting of a notice with dimensions of at least 15 cm x 20 cm, and the following content in Chinese and Portuguese:

“SMOKING ROOM”

7. Smoking rooms are not to be used two hours prior to their respective cleaning.
8. The ventilation system of the smoking rooms must be kept in operation during all of the time that they are being cleaned.
9. It is prohibited to engage in any other activities besides smoking, even temporarily.
10. Smoking rooms are subject to the legislation in force, notably Fire Prevention Safety Regulations.
11. This order enters into force on January 1, 2012.

December 6, 2011.

Chief Executive, *Chui Sai On*.