

**Appendix:** Result of Inspection of the Establishment of Indoor Smoking Rooms

Date of Inspection:			
Address of Inspected Place:			
Establisher	Name		
	Telephone No.		FAX
Inspector	Name		
	Telephone No.		FAX
	Licence No.		
Inspected Items		Result of Inspection	
1. The area is no less than 6 square meters and no more than 35 square meters.			
2. The area is no more than 20% of the total area of the premise.			
3. Is an independent compartmentalized room.			
4. With independent ventilation systems.			
5. The entrances and exits thereof are designed as being horizontal sliding mode and able to close automatically.			
6. The atmospheric pressure thereof is negative and over 0.816 mmH <sub>2</sub> O <sub>8</sub> (8 Pascal)			

<p>7. The quantity of ventilation thereof per hour is more than 30 cubic meters per square meter of the floor area. (The amount of fresh air provided per hour is at least 10 times the volume of the Smoking Room.)</p>	
<p>8. The ventilation pipes shall be positioned 5 meters or more away from the entrances and exits of the building, other building, or any places where smoking is prohibited by law.</p>	
<p>Overall Inspection Result</p>	

Establisher:

Signature:

Inspector:

Signature: